

DO NOT SCALE THIS DRAWING.

Notes

- DO NOT SCALE FROM THIS DRAWING, IF IN DOUBT, REQUEST FURTHER INFORMATION.
- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE MAIN CONTRACT CONDITIONS, THE BUILDING SERVICES SPECIFICATIONS AND SCHEDULES, THE ARCHITECT'S AND STRUCTURAL ENGINEER'S DRAWINGS.
- REFER TO THE ARCHITECT'S DRAWINGS FOR DETAILS OF ALL SETTING OUT INFORMATION. NO DIMENSIONS SHALL BE MEASURED FROM THIS DRAWING.
- REFER TO THE ARCHITECT'S REFLECTED CEILING PLANS FOR THE SETTING OUT OF ALL SOFFIT MOUNTED SERVICES COMPONENTS.
- REFER TO THE ARCHITECT'S DRAWINGS FOR DETAILS OF ALL BUILDING COMPARTMENTATION. ALL SERVICES SHALL BE FIRE SEALED USING THE APPROVED PENETRATION DETAIL, FULLY IN ACCORDANCE WITH THE COMPARTMENT RATING.
- ALL OUTLETS IN CONCRETE WALLS AND COLUMNS TO HAVE CONDUIT AND BACK-BOXES CAST IN AS ARCHITECT'S AND STRUCTURAL ENGINEER'S DETAILS.
- FLOORBOX LOCATIONS AND NUMBERS IN OFFICE AREAS ARE INDICATIVE ONLY AND SHALL DEPEND ON FINAL ROOM LAYOUTS.
- WHERE REQUIRED, CONDUIT & BACK-BOXES SHOULD BE CAST INTO SLAB AS DETAIL xxxx.

LEGEND

- SINGLE 13A SWITCHED SOCKET
- TWIN 13A SWITCHED SOCKET
- '7' No. OF SOCKET OUTLETS
- IP65 RATED SINGLE BS4343 SOCKET OUTLET
- UNSWITCHED FCU
- SWITCHED FCU
- DOUBLE POLE SWITCH. MODULE
- ENGRAVED FRIDGE / COOKER, ETC AS APPROPRIATE
- DISTRIBUTION BOARD
- THREE PHASE OUTLET
- BUSBAR TRUNKING SYSTEM
- END FEED FOR BUSBAR
- 3 COMPARTMENT DADO TRUNKING
- ISOLATOR
- DATA AND POWER HUB C/W FLOORBOX LIO IN FLOOR TILE ABOVE
- HEAVY DUTY STEEL FLOORBOX WITH STONE INSERT TO MATCH ARCHITECTURAL FINISH.
- 4 COMPARTMENT FLOORBOX FOR SUSPENDED FLOOR AND C/W UMBILICAL HOSE TO CARRY 2No. POWER CABLES AND 12No. DATA CABLES. INSERT TO MATCH ARCHITECTURAL FINISH.
- CIRCULAR POWER GROMMET WITH 1No. 13A SOCKET
- TELEPHONE POINT
- DATA POINT
- TELEVISION POINT
- WLAN ACCESS POINT MOUNTED AT H/L
- MICROPHONE POINT


A	ISSUED FOR TENDER	MAR 05	REM	APF
0	ISSUED FOR BILLING	JAN 05	REM	APF
Rev	Description	Date	Dm	Chd

TENDER

Status of drawing

Four Winds
Pacific Quay
Glasgow G51 1DY

Tel: +44 (0)141 419 3000
Fax: +44 (0)870 787 4146
Email: 008209@burohappold.com
Web: www.burohappold.com



Buro Happold
Consulting Engineers

Architect: Bennetts Associates / Relach and Hall

Project: **The University of Edinburgh - Potterrow**
Ground Floor - Phase 1
Small Power, Data & Comms
General Arrangement

Scale: A1 1:125

Drawn by: REM
Checked by: APF

Date: November 2004

Job No: **008209**

Drawing No: **E 111**

Rev: **A**

